

Interactive
Comment

Interactive comment on “Low-cost multi-stage filtration enhanced by coagulation-flocculation in upflow gravel filtration” by L. D. Sánchez et al.

Anonymous Referee #2

Received and published: 24 October 2012

This paper "Low-cost multi-stage filtration enhanced by coagulation-flocculation in upflow gravel filtration" assesses the operational and design aspects of coagulation and flocculation in upflow gravel filters (CF-UGF) in a multi-stage filtration (MSF) plant. Paper was aloud written and visibly is the flexibility of the system to operate with and without coagulant according to the influent turbidity. Suggestion: - performed other hydrodynamic model. In the hydrodynamic model was performed only CMRS model (in Reactor Engineering literature named Tank in series model) but not performed other models (e.g. Dispersion model). Considering that only 51% of tank reactor was perfect mixed for determination influence of dispersion should be determined Peclet number. - To check balance of tracer and confirmed that not involved in any of the physical and chemical processes. Syntax mistake in paper: - Fig. 4. X-axis not correctly described In Chem. Eng. literature ratio t/t_0 need to write as lowercase letter and it is

C207

[Full Screen / Esc](#)

[Printer-friendly Version](#)

[Interactive Discussion](#)

[Discussion Paper](#)



dimensionless time. Uppercase letter T is symbol for Temperature.

Interactive comment on Drink. Water Eng. Sci. Discuss., 5, 291, 2012.

DWESD

5, C207–C208, 2012

Interactive
Comment

Full Screen / Esc

Printer-friendly Version

Interactive Discussion

Discussion Paper

C208

