Drink. Water Eng. Sci. Discuss., 7, C25–C26, 2014 www.drink-water-eng-sci-discuss.net/7/C25/2014/

© Author(s) 2014. This work is distributed under the Creative Commons Attribute 3.0 License.



DWESD

7, C25-C26, 2014

Interactive Comment

Interactive comment on "A pipe network simulation model with dynamic transition between free surface and pressurized flow" by J. Fernández-Pato and P. García-Navarro

Anonymous Referee #2

Received and published: 11 March 2014

In this article the authors present a method to simulate pressurized and unpressurized flow in distribution networks. The manuscript needs a major revision before being published. I have some general comments:

- 0) I miss a concise and clear explanation regarding the relevance of this work: in which situation are pressurized and unpressurized flows relevant?
- 1) I do understand that English is not the authors' mother tongue, but the article would benefit from a review made by a native speaker.
- 2) Each parameter that you introduce in your work has to be identified and its units must be given, otherwise it becomes very difficult to follow the work.

Full Screen / Esc

Printer-friendly Version

Interactive Discussion

Discussion Paper



Detailed comments:

Page 30, Eq. 3: what are "eta" and "h"?

Page 31, line 19: I find the reference to speed of sound in gases irrelevant.

Page 32, Eq. 13: please indicate clearly that "lambda"=eigenvalues and that "e"=eigenvectors.

Page 32, line 5: I find the reference to Mach nr irrelevant.

Page 32, line 7: Water hammer is presented for the first time in Section 2.2 without being properly introduced. How does water-hammer relate to the situation being studied?

Page 32, line 21: why do you neglect the convective term?

Page 32, Eq. 15: what is "rho"?

Page 34, Eq. 22: What is parameter "bS"?

Page 36, Eq. 36: what are you assuming here?

Page 36, line 15: a "sometimes a storage well junction is used", for what?

Page 37, line 4: what is a "bump"? It had not yet been defined.

Page 53, 54, Fig. 9 and Fig. 10: Please translate the labels of the Y-axis.

Page 55, Fig. 11: please make the Y-axis labels consistent with the ones of Fig.9 and Fig. 10.

Interactive comment on Drink. Water Eng. Sci. Discuss., 7, 27, 2014.

DWESD

7, C25-C26, 2014

Interactive Comment

Full Screen / Esc

Printer-friendly Version

Interactive Discussion

Discussion Paper

