

Interactive comment on “The Ability of Froth Formed without Chemicals to Hold Bacteria” by Ghanim Hassan and Robert G. J. Edyvean

Ghanim Hassan and Robert G. J. Edyvean

dr.ghanim@mtu.edu.iq

Received and published: 13 February 2019

Most of the comments were being taken into revision. Again, I suffered a lot as the line numbers did not indicate the relevant comments but I did my best. If there are any further comments, please let me know.

Interactive comment on Drink. Water Eng. Sci. Discuss., <https://doi.org/10.5194/dwes-2018-27, 2019>.

C1

1 **The Ability of Froth Formed without Chemicals to Hold Bacteria**
2
3 Dr. Ghanim Hassan*, Department of Water Resources Techniques, Middle Technical University,
4 Baghdad, Iraq, dr.ghanim@mtu.edu.iq
5 Dr. Robert G. J. Edyvean, Department of Chemical and Biological Engineering, The University
6 of Sheffield, Sheffield, UK, r.edyvean@sheffield.ac.uk
7
8 Key words: Froth flotation, Bacterial Bio-purification, Drinking water
9
10 **Abstract**
11 Froth flotation is a solid-liquid separation technique that uses hydrophobicity as a driving force.
12 Bacteria and other drinking water microorganisms tend to be hydrophobic and can be removed
13 from water using this application. The biggest limitation against using froth flotation in the
14 drinking water industry is the difficulty of producing froth without chemical “frothers” and holding
15 bacteria in this froth without chemical collectors which deteriorate water taste and odor. Recently,
16 researchers at the University of Sheffield described a method for producing froth using only water
17 and compressed air (Hassan, 2015). This has enabled froth flotation to be studied as an alternative
18 to biocides for the removal of bacteria from drinking water.
19 This work examines the ability of froth, produced by controlling air pumping through a water
20 column, to hold bacteria. Bacteria are moved to the top of the column and collected in the froth.
21 The operating conditions determine the percentage of bacteria removed.
22 At optimum conditions, froth can hold up to 2×10^8 cfu/ml of bacteria. It has been found that air
23 pumping at 130 l/min in a 20 cm diameter column will give the highest froth bacterial content.
24 Time to reach stable froth bacterial concentration is decreased by increasing other variables.
25 * Correspondence Author: Dr. Ghanim Hassan, dr.ghanim @mtu.edu.iq, 00964-
26 7704335364.
27

Fig. 1.

C2